

**Sent:** Wednesday, December 11, 2013 7:50 AM  
**Subject:** FW: VTEMP Recommissioning

-----Original Message-----

From: [brivera@nisource.com](mailto:brivera@nisource.com)

Subject: VTEMP Recommissioning

Jason / Mike,

We successfully completed the recommissioning of the VTEMP system today.

The automatic control feature, our previous nemeses, was tested and I am happy to report, now controls without incident.

We were able to control down to 240 MW Gross with no issues, all while maintaining SCR EGOT well above the required ammonia injection limits.

I want to say today's effort was only a success because of a fantastic multidiscipline team and the cooperation and input of all parties involved. Hats off to the control room personnel, B & W, Invensys, RJ Mycka, Major Projects, Dispatch, I & C, and Larry Bross for making this a safe recommissioning.

Thank you,

Bruce Rivera  
Construction Manager Major Projects