

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011703-R1  
**DATE:** 11/04/2013  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Maxim  
**CODE:** M-1256-1  
**REVISION DATE:** 08/21/2017

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Maxim Industries, Inc.</b> <b>1630 Terre Colony Court</b> <b>Dallas, TX 75212</b>	<b>Unit Skylight Plastic Glazed Skylight</b> <b>Self Flashing or Curb Mounted</b>  Configuration: O  Glazing: Exterior Dome-1/8" Polycarbonate/Interior Dome-1/8" Polycarbonate  Overall: W-1540mm(60.63") H-1556mm(61.25") DLO: W-1483mm(58.40") H-1432mm(56.40")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>ASTM E1886-05/E1996-05</b> <b>TAS 201/202/203-94</b>	<b>CW-PG40 1559 x 2477 (61 x 98) SKP/RW</b> <b>Design Pressure: 1920 Pa (40 psf)</b> <b>Negative Design Pressure: 3600 Pa (75 psf)</b> <b>Wind Zone 4 - Missile Level D</b> <b>Large Missile Impact Rated</b>

Product Tested By: Architectural Testing, Inc.  
Report No: D1032.03-801-44/D1032.02-801-44/D1032.01/801-44  
Expiration Date: September 30, 2021

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122